



January 25, 2008

Charlie Cary
Biomass Combustion Systems
67 Millbrook Street, #505
Worcester, MA 01606

**RE: Wood Furnace Emissions Testing Results
CK Project 3225**

Dear Mr. Cary:

CK Environmental, Inc. (CK) performed particulate matter (PM), condensable particulate matter (CPM), nitrogen oxides (NO_x), and carbon monoxide (CO) emissions testing of a 36" Shop Heater with a heat input rating of 999,000 BTU/hr using EPA Reference Methods 1-5/202, 7E and 10. Furnace emissions exhausted to the atmosphere through a 12 inch (nominal) diameter stack. This report presents the results of testing performed December 5, 2007.

The subject unit burns milled wood scraps from a sash and window manufacturing process. A representative sample of wood was submitted to Desert Analytics for analysis. A copy of the analytical report is located in Appendix B. The heating value of the sample "as received" by the laboratory was 8,474 BTU/lb. This value was used to calculate pollutant emission rates (lbs/MMBtu).

Three 1-hour test runs were performed. PM and CPM samples were submitted to Maxxam Analytical, Inc. for analyses. Table 1 presents a summary of results. The heat input during testing averaged 0.94 MMBtu/hr which resulted in an average total particulate (PM & CPM) emission rate was 0.086 lbs/MMBtu. NO_x emissions averaged 0.050 lbs/MMBtu.

Sampling was conducted by trained personnel with extensive experience in Reference Method sampling. All sampling and analyses were conducted in strict accordance with the following EPA test procedures, including quality control procedures found in the EPA Quality Assurance Handbook for Air Pollution Measurement Systems.

EPA Methods 1-5	- Determination of Particulate Matter (PM) Emissions from Stationary Sources
EPA Method 3A	- Determination of Oxygen (O ₂) and Carbon Dioxide (CO ₂) Concentration Emissions from Stationary Sources
EPA Method 7E	- Determination of Nitrogen Oxide (NO _x) Emissions from Stationary Sources
EPA Method 10	- Determination of Carbon Monoxide (CO) Emissions from Stationary Sources
EPA Method 202	- Determination of Condensable Particulate Matter (CPM) from Stationary Sources

CK's entire equipment inventory is on a schedule of routine maintenance and calibration. All calculations were conducted in accordance with the equations found in the individual Methods. Emission rate calculations were checked by a second individual to ensure that they are correct. These specific procedures validate the results obtained during the test program. The majority of CK's emissions testing work is performed for compliance purposes, which require strict



QC procedures. This testing program was performed using those same procedures.

Supporting documentation is enclosed with this report. Field data sheets together with reduced data worksheets are located in Appendix A. Appendix B contains laboratory reports.

Please contact me (toll free 888-CKE-0303 or kkelley@ckenvironmental.com) should you have any questions regarding the performance, or finding, of this testing program.

Sincerely,

Kevin J. Kelley
Program Manager



Table 1 – Summary of Results

TEST NUMBER: DATE: START TIME :		1 12/6/2007 0951	2 12/6/2007 1133	3 12/6/2007 1420	AVERAGE
PROCESS CONDITIONS	UNITS				
Wood Feed Rate	lb/hr	120	107	107	111
SAMPLE CONDITIONS					
Meter Volume	dscf	45.50	46.31	44.93	45.58
Isokinesis	%	99.7	99.6	98.2	-
Total Particulate Catch	mg	52.1	52.5	41.2	-
STACK CONDITIONS					
Stack Gas Flowrate	dscf/min	580	590	580	580
Average Stack Temperature	°F	198	201	175	191
Water Vapor in Stack Gas	%	2.5	3.2	3.1	3.0
CO ₂ in Stack Gas	%	3.9	2.4	2.6	3.0
O ₂ in Stack Gas	%	16.6	18.3	17.9	17.6
CO in Stack Gas	ppm	315	485	205	335
MEASURED EMISSIONS					
NO _x in Stack Gas	ppm	14.1	9.1	11.0	11.4
NO _x Emission Rate	lbs/hr	0.059	0.038	0.046	0.048
NO_x Emission Rate	lb/MMBtu	0.058	0.042	0.050	0.050
Particulate Emission Concentration	gr/dscf	0.0177	0.0175	0.0142	0.0164
Mass Emission Rate	lbs/hr	0.087	0.088	0.070	0.08
Fuel Heating Value	BTU/lb	8474	8474	8474	8474
Heat Input	MMBTU/hr	1.017	0.907	0.907	0.943
Particulate Emissions	lb/MMBtu	0.086	0.097	0.077	0.086





APPENDIX A

FIELD DATA SHEETS

EPA Method 1

Sample and Velocity Traverses
for Stationary Sources

Firm BIOMASS COMBUSTION @ BOSTON ASHT Total Traverse Points Required 12
 Date 12/5/07 Project No. _____ Number of Ports _____
 Location WOOD-FIRED FURNACE STACK Points Per Port 2
 Diameters Upstream 3 Probe Traverses: Horizontal _____
 Diameters Downstream 76 Vertical _____



Point On A Diameter	Location of Traverse Points in Circular Stacks* Number of Traverse Points on a Diameter					Traverse Point Location		
	4	6	8	10	12	Distance From Wall	Nipple Size	Total Distance
1	6.7	4.4	3.2	2.6	2.1	0.5	2" ↓	2.5
2	25.0	14.6	10.5	8.2	6.7	1.8		3.8
3	75.0	29.6	19.4	14.6	11.8	3.6		5.6
4	93.3	70.4	32.3	22.6	17.7	8.5		10.5
5		85.4	67.7	34.2	25.0	10.4		12.4
6		95.6	80.6	65.8	35.6	11.6		13.6
7			89.5	77.4	64.4			
8			96.8	85.4	75.0			
9				91.8	82.3			
10				97.4	88.2			
11					93.3			
12					97.9			

*Percent of Stack Diameter from Inside Wall to Traverse Point




ESZ 1.6676
 AHE +0.0898
 Y = 0.9942
 1.0083

EPA Method 2

Velocity Traverse and
 Flow Rate Determination

Firm: Biomass Combustion @ Boston SASH
 Date: 12/6/07 Project No. _____
 Location: Woodfired furnace stack
Round Stack or Duct:
 Diameter (in): 12 1/8" (12.125") Area _____ ft²
Rectangular Stack or Duct:
 Stack Length (in) _____ Area _____ ft²
 Stack Width (in) _____
 Barometric Pressure; Pb = _____ in. Hg
 Stack Static Pressure; Pg = 0.04 in. H2O
 Stack Gas Moisture Content; % H2O = _____
 Stack Gas Molecular Weight; (wet) Mw = _____
 Pitot Tube No. _____ Cp = 0.84
 Field Tester(s) _____
 Test Start Time: _____ Finish: _____

Pre-test flow



Cyclonic Flow Angle: + Ø Clockwise
 - Ø Counterwise

PORT	POINT	dP (Inch H2O)	SqRoot dP	Ts (°F)	± Ø	Pitots Reversed for Negative Flow?	RADIANS	SqR dP*cosØ
A	1	0.06		108				
	2	0.065		125				
	3	0.07		136				
	4	0.065		141				
	5	0.065		144				
	6	0.055		136				
B	1	0.05		94				
	2	0.06		104				
	3	0.065		116				
	4	0.07		121				
	5	0.06		126				
	6	0.05		124				
AVERAGE							AVERAGE	

Absolute Gas Temperature; $T_{st} = T_s + 460^\circ$
 Absolute Gas Pressure; $P_s = P_b + P_g/13.6$
 Gas Velocity; $V_s = (85.49)C_p(??P*cosØ)_{avg}(T_{st} avg/(P_s*M_w))$
 Actual Gas Flow Rate; $Q_a = (V_s)(60)(A)$
 Standard Gas Flow Rate; $Q_s = Q_a(528^\circ R/T_{st})(P_s/29.92)$
 Dry Standard Gas Flow Rate; $Q_{sd} = Q_a(528^\circ R/T_{st})(P_s/29.92)((100-\%H_2O)/100)$

_____ ° R
 _____ in. Hg
 _____ ft/sec
 #VALUE! acfm
 _____ scfm
 _____ dscfm

EPA Method 5

Particulate Test Data Sheet

Client/Firm: BIO MASS COMBUSTION
 Location: WOODFORD GREENHOUSE STACK
 Project No.: 1
 Test Number: 1
 Test Date: 12/6/07
 Start Time: 04:51
 End Time: 5
 Testers Initials: 62
 Min Per Point: 5

Assumed Moisture: 5 (%)
 Pb = 0.441 (in Hg)
 Nozzle Size: 0.441
 Nozzle No.: J55006
 C/K Factor: 29.14

Module No.: ES2
 dH@ = 1.0676
 Cp = 0.84
 Y = 1.0080

Signature of Train Operator:

Rectangular Stack: Length (in) _____
 Circular Stack: Diameter (in) _____
 Train Leak Checks: Pre-Test _____ Post-Test _____
 Orsat Leak Check: Pre-Test _____
 Pitot Leak Check: Pre-Test _____
 Final Orsat Analysis: _____

Width (in) _____
 Area (ft²) 40.00
 Train Leak Checks: Pre-Test _____ Post-Test _____
 Orsat Leak Check: Pre-Test _____
 Pitot Leak Check: Pre-Test _____
 Final Orsat Analysis: _____

Port	Point	Time (min)	Meter Volume (ft ³)	dP (in. H2O)	dH (in. H2O)	Stack (°F)	Probe (°F)	Htr Box (°F)	Temperatures		Cond. Out (°F)	Module Meter		Vacuum (in. Hg)	Comments
									Filter (°F)	Out (°F)		In (°F)	Out (°F)		
A	1	0	271.28	0.01	2.04	342	337		212		34	40	34	2	Static Pressure: in H2O
	2	5	275.4	0.07	2.04	335	239		232		34	43	35	3	dp 0.045 1.31
	3	10	279.0	0.60	1.89	226	237		234		36	44	36	3	0.05 1.46
	4	15	283	0.60	1.75	204	237		230		39	46	37	3	0.055 1.60
	5	20	286.4	0.55	1.6	184	236		236		41	46	38	3	0.06 1.75
	6	25	289.4	0.05	1.46	93	239		237		42	47	39	3	0.065 1.89
	30		143												
B	1			0.05	1.46	93	237		236		44	47	39	3	0.07 2.04
	2		246.2	0.05	1.46	162	239		237		44	47	39	3	0.075 2.19
	3		299.5	0.055	1.6	184	239		236		46	47	39	3	
	4		302.6	0.06	1.75	224	239		237		48	49	40	3	
	5		306	0.07	2.04	270	239		237		48	49	41	6	
	6		310.0	0.07	2.04	270	240		240		52	51	43	6	
	END		313.911												

Average

Avg Square Root dP

Final Reading: _____
 Total Volume: _____

Average of In & Out Meter Temperatures

Impinger Number	Impinger Recovery		Total Catch
	Vol or Wt	Final	
1	100	103	3
2	100	109	9
3	0	2	2
4			
Other(s)			
Silica Gel	702.8	713.5	10.7

EPA Method 5

Particulate Test Data Sheet

Client/Firm
BIO MASS COMBUSTION
@ BOSTON SAST

Location WOOD FIBER FURNACE STACK
Project No. 2
Test Number 2
Test Date 12/6/07
Testers Initials WV
Start Time 11:33
End Time 11:48
Min Per Point 5

Assumed Moisture Pb =
Moisture (in Hg) 0.441
Nozzle Size 15S006
Nozzle No. 29.14
C/K Factor

Signature of Train Operator:

Module No. ESZ
dH@ = 1166.76
Cp = 0.824
Y = 1.0080
Probe No. M5-16
Pilot No.
Filter No. Z00609D604

Rectangular Stack: Length (in) Width (in)
Circular Stack: Diameter (in) 12.125 Area (ft²) 0.00
Train Leak Checks: Pre-Test 0.01 cfm Post-Test 17 in Hg
Orsat Leak Check: Pre-Test Post-Test
Pilot Leak Check: Pre-Test Post-Test
Final Orsat Analysis O2% 02% CO2%

Port Point	Time (min)	Meter Volume (ft ³)	dP (in H2O)	dH (in H2O)	Temperatures (°F)				Module Meter In (°F)	Module Meter Out (°F)	Vacuum (in Hg)	Comments
					Stack (°F)	Probe (°F)	Htr Box (°F)	Filter (°F)				
1	0	314.257	0.07	2.04	209	255	210	210	37	47	5	Static Pressure: in H2O
2	5	318.1	0.07	2.04	213	254	232	232	41	49	6	dp
3	10	321.9	0.07	2.04	219	255	236	236	43	51	7	
4	11:48:15	325.8	0.06	1.75	247	253	236	236	44	51	6	0.045
5	11:52:20	329.4	0.06	1.75	232	254	239	239	46	52	6	0.05
6	11:58:25	332.9	0.05	1.46	151	255	236	236	49	52	5	0.55
7	12:03:30	336.3	0.05	1.44	90	257	237	237	51	52	5	0.6
8	12:08:35	339.4	0.05	1.46	142	255	240	240	52	52	6	0.65
9	12:13:40	342.6	0.06	1.15	164	257	239	239	54	53	8	0.7
10	12:18:45	346.7	0.07	2.09	145	257	234	234	55	53	9	0.75
11	12:23:50	350.1	0.07	2.44	239	257	246	246	55	53	10	
12	12:28:55	354.0	0.07	2.04	246	257	240	240	58	54	10	
END	12:33:00	357.851										
											Average of In & Out Meter Temperatures	
											Average	
											Avg Square Root dP	
Final Reading:												
Total Volume:												
Impinger Recovery												
Impinger Number	Vol or Wt		Total									
	Initial	Final	Initial	Catch								
1	679.6	182.1	2.5	2.5								
2	689.8	704.1	14.5	14.5								
3	506.6	530.7	46	46								
4												
Other(s)												
Silica Gel	806.3	818.3	12	12								

Total Moisture Catch: 32.9
Calculated Moisture Content: 32.9

EPA Method 5

Particulate Test Data Sheet

Signature of Train Operator:

Rectangular Stack: Length (in) _____ Width (in) _____
 Circular Stack: Diameter (in) 12.125 Area (ft²) 0.00
 Train Leak Checks: Pre-Test 0 cfm Post-Test 10 in Hg
 Orsat Leak Check: Pre-Test 0 cfm Post-Test 12 in Hg
 Pitot Leak Check: Pre-Test _____ Post-Test _____
 Final Orsat Analysis 02% CO2%

Module No. ES2

dH@ = 1.676
 Cp = 0.84
 Y = 1.0080
 Probe No. M5-10
 Pitot No. _____
 Filter No. 200601005

Assumed Moisture

Pb = _____
 Nozzle Size 0.441
 Nozzle No. 155016
 C/K Factor 29.14

Client/Firm

Location BIO MASS COMBUSTION @ BOSTON SOUTH
 Project No. 11000-firco furnace SPKX
 Test Number 3
 Test Date 12/6/07
 Start Time 1420
 End Time _____
 Testers Initials KK
 Min Per Point 5

Port	Point	Time (min)	Meter Volume (ft ³)	dP (in H2O)	dH (in H2O)	Stack (°F)	Probe (°F)	Htr Box (°F)	Temperatures		Vacuum (in. Hg)	Comments
									Filter (°F)	Cond Out (°F)		
A	1	1420	358.052	0.63	1.89	194	253	218	36	42	42	Static Pressure: in H2O
	2	1425	361.8	0.60	1.75	197	254	232	39	44	42	
	3	1430	365.3	0.60	1.75	219	253	234	42	46	41	dH
	4	1435	368.9	0.60	1.75	202	253	234	42	47	41	0.45
	5	1440	372.4	0.50	1.46	158	255	236	40	49	42	0.50
	6	1445	375.7	0.45	1.31	74	255	236	47	49	42	0.55
	6	1450	378.9	0.45	1.31	65	254	240	48	49	43	0.60
	5	1455	382.0	0.5	1.46	98	253	237	50	49	43	0.65
	4	1505	385.7	0.55	1.6	172	256	237	53	49	43	0.70
	3	1505	388.6	0.65	1.89	233	255	234	57	50	43	0.75
	2	1510	392.3	0.70	2.04	249	226	233	59	51	44	
	1	1515	396.1	0.70	2.04	235	254	232	59	51	44	
	END	1720	400.044									
Average of In & Out Meter Temperatures												
Average												
Avg Square Root dP												
Final Reading:												
Total Volume:												

Impinger Number	Impinger Recovery		Total Catch
	Vol or Wt	Final	
1	715.6	715.7	8.1
2	724.3	737.6	15.3
3	523.2	527.8	4.6
4			
Other(s)			
Silica Gel	785.3	796.8	11.5

Total Moisture Content: 31.5

Total Moisture Catch: _____



WOOD WAD

Run 1 = 20 lb/10 min

Run 2+3 = 17 lb/10 min

SYSTEM CALIBRATION SHEET

PLANT: BOSTON SASH/BIO MASS COMB DATE: 12/6/07
 TEST LOCATION: BIO MASS BUR OPERATOR: MK
 FUEL: WOOD SYSTEM RESPONSE TIME: _____

		O ₂		CO ₂		CO		SO ₂		NO _x	
		RANGE: ZERO	SPAN	RANGE: ZERO	SPAN	RANGE: ZERO	SPAN	RANGE: ZERO	SPAN	RANGE: ZERO	SPAN
RUN: <u>1</u> START TIME: <u>09:50</u> END TIME: <u>10:50</u>	ANALYZER CAL RESPONSE	0.1	11.1	0.0	11.2	0.1	292			0.2	251.0
	INITIAL SYSTEM CAL RESPONSE	0.7	10.7	0.0	11.0	2.6	282			0.7	246
	SYSTEM BIAS	0.0	1.6	0.0	0.0	0.5	2.0			0.10	1.0
	FINAL SYSTEM CAL RESPONSE	0.0	10.5	0.4	11.1	3.2	279.5			0.7	250.6
	SYSTEM BIAS	0.4	2.4	2.0	0.5	0.6	2.7			0.1	0.1
	SYSTEM DRIFT	0.4	0.8	2.0	0.5	0.1	0.5			0.0	0.9
NON CAL. CORR. AVERAGE		16.6		3.9		315.3				14.1	
RUN: <u>2</u> START TIME: <u>11:33</u> END TIME: <u>12:33</u>	INITIAL SYSTEM CAL RESPONSE	0.0	10.5	0.4	11.1	3.2	279.5			0.7	250.6
	SYSTEM BIAS	0.4	2.4	2.0	0.5	0.6	2.7			0.1	0.1
	FINAL SYSTEM CAL RESPONSE	0.2	10.8	0.0	10.7	4.0	278.5			0.2	238.5
	SYSTEM BIAS	0.4	1.2	0.0	2.5	0.8	2.8			0.0	2.7
	SYSTEM DRIFT	0.8	1.2	2.0	2.0	0.2	0.2			0.1	2.6
	NON CAL. CORR. AVERAGE		18.3		2.4		485.				9.1
RUN: <u>3</u> START TIME: <u>14:20</u> END TIME: _____	INITIAL SYSTEM CAL RESPONSE	0.2	10.8	0.0	10.7	4.0	278.5			0.2	238.5
	SYSTEM BIAS	0.4	1.2	0.0	2.5	0.8	2.8			0.0	2.7
	FINAL SYSTEM CAL RESPONSE	0.3	10.6	0.2	10.5	3.6	282.1			0.6	241.5
	SYSTEM BIAS										
	SYSTEM DRIFT										
	NON CAL. CORR. AVERAGE		17.9		2.6		204.5				11.0

SYSTEM BIAS = [(SYSTEM RESPONSE - ANALYZER RESPONSE) / HIGH CYLINDER VALUE] * 100

ERROR MUST NOT EXCEED 5% OF HIGH CYLINDER VALUE

SYSTEM DRIFT = [(INITIAL SYSTEM RESPONSE - FINAL SYSTEM RESPONSE) / HIGH CYLINDER VALUE] * 100

ERROR MUST NOT EXCEED 3% OF HIGH CYLINDER VALUE

- MONARCH TIME = 1 HR AHEAD OF ACTUAL
- Run 2 @ REDUCED FEED RATE



ANALYZER CALIBRATION SHEET

PLANT: Biomass Comb @ Boston SASH DATE: 12/6/07
 TEST LOCATION: Biomass BLR OPERATOR: MK
 FUEL: WOOD

GAS	RANGE	CYLINDER VALUE	ANALYZER RESPONSE	ABSOLUTE DIFFERENCE	ANALYZER CAL. ERROR
O ₂	ZERO	0.0	0.1	0.1	0.4
	MID	10.96	11.1	0.1	0.4
	HIGH	21.1	21.0	0.1	0.4
CO ₂	ZERO	0.0	0.0	0.0	0.0
	MID	11.12	17.6 ^{11.2}	0.1	0.5
	HIGH	17.6	17.6	0.0	0.0
CO	ZERO	0.0	0.1	0.1	0.0
	MID	292	292	0.0	0.0
	HIGH	496	492.0	4.0	0.8
SO ₂	ZERO	0.0			
	MID				
	HIGH				
NOx	ZERO	0.0	0.2	0.2	0.1
	MID	245	251.0	6.0	1.2
	HIGH	503	499.9	3.1	0.6


ANALYZER CALIBRATION ERROR = [(ANALYZER RESPONSE - CYLINDER VALUE) / HIGH CYLINDER VALUE] * 100

ERROR MUST NOT EXCEED 2% OF HIGH CYLINDER VALUE



APPENDIX B

LABORATORY REPORT



November 29, 2007

Client: CK Environmental, Inc.
 1020 Turnpike St.
 Suite 8
 Canton, MA 02021

Attn: Becky Travis

Project: PO 3670RGT

Date Received: November 12, 2007

Certificate of Analysis

Analyses	Method	Sample ID	Wood Fuels 12 blocks					
		Date/Time						
		Lab #	DA07-8874					
		units	As Received	Moisture Free	As Received	Moisture Free	As Received	Moisture Free

Proximate Analysis

Moisture E871 % 5.42
 Ash D1102 % 0.49 0.51

Ultimate D3176

Carbon % 47.96 50.71
 Hydrogen % 6.21 5.92
 Nitrogen % 0.06 0.06
 Oxygen % 45.27 42.77
 Sulfur % 0.012 0.012

Heating Value D5865 BTU/lb 8,474 8,960

Notes:

Ralph V. Poulsen, Lab Director

3860 S. Palo Verde Rd.
 Suite 303
 Tucson, AZ 85714
 520.623.3381

Your Project #: 3225
Site: BOIMASS COMBUSTION

Attention: Kevin Kelley
CK ENVIRONMENTAL
1020 Turnpike St
Unit 8
Canton, MA
USAE 2021

Report Date: 2008/01/03

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A7D8796
Received: 2007/12/13, 12:00

Sample Matrix: Filter
Samples Received: 3

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Particulates in Acetone Rinse (M5/315)	3	2007/12/27	2008/01/02	BRL SOP-00109	EPA 5/315
Particulates on Filter (M5/315/NJATM1)	3	2007/12/19	2007/12/22	BRL SOP-00109	EPA 5/315/NJATM1
Final Volume of Acetone Probe Rinse	3	2007/12/21	2007/12/27		

Sample Matrix: Impinger Solution
Samples Received: 6

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Extractable Condensables (M202)	3	2007/12/22	2007/12/30	BRL SOP-00118	EPA 202
Non Extractable Condensables (M202)	6	2007/12/27	2008/01/02	BRL SOP-00118 / BRL SOP-00109	EPA 202
Volume of DCM Received	3	2007/12/22	2007/12/22		
Final Volume of Impinger	6	2007/12/22	2007/12/22		

MAXXAM ANALYTICS INC.

ANCY SEBASTIAN, C.Tech.
Senior Project Manager, Air Toxics

AMS/ams
encl.

..12

Your Project #: 3225
Site: BOIMASS COMBUSTION

Attention: Kevin Kelley
CK ENVIRONMENTAL
1020 Turnpike St
Unit 8
Canton, MA
USAE 2021

Report Date: 2008/01/03

CERTIFICATE OF ANALYSIS

-2-

PM Released by :


ANCY SEBASTIAN, C.Tech.
Senior Project Manager, Air Toxics

Total cover pages: 2

Maxxam Job #: A7D8796
Report Date: 2008/01/03

CK ENVIRONMENTAL
Client Project #: 3225
Project name: BOIMASS COMBUSTION
Sampler Initials:

RESULTS OF ANALYSES OF FILTER

Maxxam ID		W41526	W41527	W41528		
Sampling Date		2007/12/06	2007/12/06	2007/12/06		
	Units	RUN 1	RUN 2	RUN 3	RDL	QC Batch
Particulate Weight in Acetone Rinse	mg	8.7	4.0	3.9	0.5	1434814
Volume	ml	69	63	80	1	1433658
Particulate Weight on Filter	mg	31.7	33.6	26.0	0.30	1433657
RDL = Reportable Detection Limit QC Batch = Quality Control Batch						

Maxxam Job #: A7D8796
Report Date: 2008/01/03

CK ENVIRONMENTAL
Client Project #: 3225
Project name: BOIMASS COMBUSTION
Sampler Initials:

RESULTS OF ANALYSES OF IMPINGER SOLUTION

Maxxam ID		W41530	W41531	W41532	W41533		
Sampling Date		2007/12/06	2007/12/06	2007/12/06	2007/12/06		
	Units	M202-A H2O/MECL2	M202-B H2O/MECL2	M202-C H2O/MECL2	M202-RUN 1 H2O	RDL	QC Batch

Extractable Condensibles	mg	43	2	3	N/A	1	1432143
Non-Extractable Condensibles	mg	0.9	1.3	1.4	7.8	0.5	1434806
Volume	ml	50	50	50	460	1	1433966
DCM Volume	ml	50	50	45	N/A	1	1433965

N/A = Not Applicable
RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Maxxam ID		W41579	W41580		
Sampling Date		2007/12/06	2007/12/06		
	Units	M202-RUN 2 H2O	M202-RUN 3 H2O	RDL	QC Batch

Non-Extractable Condensibles	mg	11	7.4	0.5	1434806
Volume	ml	500	420	1	1433966

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Maxxam Job #: A7D8796
Report Date: 2008/01/03

CK ENVIRONMENTAL
Client Project #: 3225
Project name: BOIMASS COMBUSTION
Sampler Initials:

Test Summary

Maxxam ID W41526 **Collected** 2007/12/06
Sample ID RUN 1 **Shipped**
Matrix Filter **Received** 2007/12/13

Test Description	Instrumentation	Batch	Prepared	Analyzed	Analyst
Particulates in Acetone Rinse (M5/315)	BAL	1434814	2007/12/27	2008/01/02	VP2
Particulates on Filter (M5/315/NJATM1)	BAL	1433657	2007/12/19	2007/12/22	HA2
Final Volume of Acetone Probe Rinse		1433658	2007/12/21	2007/12/27	VP2

Maxxam ID W41527 **Collected** 2007/12/06
Sample ID RUN 2 **Shipped**
Matrix Filter **Received** 2007/12/13

Test Description	Instrumentation	Batch	Prepared	Analyzed	Analyst
Particulates in Acetone Rinse (M5/315)	BAL	1434814	2007/12/27	2008/01/02	VP2
Particulates on Filter (M5/315/NJATM1)	BAL	1433657	2007/12/19	2007/12/22	HA2
Final Volume of Acetone Probe Rinse		1433658	2007/12/21	2007/12/27	VP2

Maxxam ID W41528 **Collected** 2007/12/06
Sample ID RUN 3 **Shipped**
Matrix Filter **Received** 2007/12/13

Test Description	Instrumentation	Batch	Prepared	Analyzed	Analyst
Particulates in Acetone Rinse (M5/315)	BAL	1434814	2007/12/27	2008/01/02	VP2
Particulates on Filter (M5/315/NJATM1)	BAL	1433657	2007/12/19	2007/12/22	HA2
Final Volume of Acetone Probe Rinse		1433658	2007/12/21	2007/12/27	VP2

Maxxam ID W41530 **Collected** 2007/12/06
Sample ID M202-A H2O/MECL2 **Shipped**
Matrix Impinger Solution **Received** 2007/12/13

Test Description	Instrumentation	Batch	Prepared	Analyzed	Analyst
Extractable Condensables (M202)		1432143	2007/12/22	2007/12/30	LJD
Non Extractable Condensables (M202)		1434806	2007/12/27	2008/01/02	VP2
Volume of DCM Received		1433965	2007/12/22	2007/12/22	LJD
Final Volume of Impinger		1433966	2007/12/22	2007/12/22	LJD

Maxxam ID W41531 **Collected** 2007/12/06
Sample ID M202-B H2O/MECL2 **Shipped**
Matrix Impinger Solution **Received** 2007/12/13

Test Description	Instrumentation	Batch	Prepared	Analyzed	Analyst
Extractable Condensables (M202)		1432143	2007/12/22	2007/12/30	LJD
Non Extractable Condensables (M202)		1434806	2007/12/27	2008/01/02	VP2
Volume of DCM Received		1433965	2007/12/22	2007/12/22	LJD
Final Volume of Impinger		1433966	2007/12/22	2007/12/22	LJD

Maxxam Job #: A7D8796
Report Date: 2008/01/03

CK ENVIRONMENTAL
Client Project #: 3225
Project name: BOIMASS COMBUSTION
Sampler Initials:

Test Summary

Maxxam ID W41532 **Collected** 2007/12/06
Sample ID M202-C H2O/MECL2 **Shipped**
Matrix Impinger Solution **Received** 2007/12/13

Test Description	Instrumentation	Batch	Prepared	Analyzed	Analyst
Extractable Condensables (M202)		1432143	2007/12/22	2007/12/30	LJD
Non Extractable Condensables (M202)		1434806	2007/12/27	2008/01/02	VP2
Volume of DCM Received		1433965	2007/12/22	2007/12/22	LJD
Final Volume of Impinger		1433966	2007/12/22	2007/12/22	LJD

Maxxam ID W41533 **Collected** 2007/12/06
Sample ID M202-RUN 1 H2O **Shipped**
Matrix Impinger Solution **Received** 2007/12/13

Test Description	Instrumentation	Batch	Prepared	Analyzed	Analyst
Non Extractable Condensables (M202)		1434806	2007/12/27	2008/01/02	VP2
Final Volume of Impinger		1433966	2007/12/22	2007/12/22	LJD

Maxxam ID W41579 **Collected** 2007/12/06
Sample ID M202-RUN 2 H2O **Shipped**
Matrix Impinger Solution **Received** 2007/12/13

Test Description	Instrumentation	Batch	Prepared	Analyzed	Analyst
Non Extractable Condensables (M202)		1434806	2007/12/27	2008/01/02	VP2
Final Volume of Impinger		1433966	2007/12/22	2007/12/22	LJD

Maxxam ID W41580 **Collected** 2007/12/06
Sample ID M202-RUN 3 H2O **Shipped**
Matrix Impinger Solution **Received** 2007/12/13

Test Description	Instrumentation	Batch	Prepared	Analyzed	Analyst
Non Extractable Condensables (M202)		1434806	2007/12/27	2008/01/02	VP2
Final Volume of Impinger		1433966	2007/12/22	2007/12/22	LJD

Maxxam Job #: A7D8796
Report Date: 2008/01/03

CK ENVIRONMENTAL
Client Project #: 3225
Project name: BOIMASS COMBUSTION
Sampler Initials:

GENERAL COMMENTS

Unable to read the label on the DCM jars. Therefore the bottles are logged as A,B,C and analyzed separately for both extractable and condensable particulate. In-house RODI water was used during extraction.

RESULTS OF ANALYSES OF FILTER

Particulates on Filter (M5/315/NJATM1): W41526-01R*LPC*
W41527-01R*LPC*
W41528-01R*LPC*

LPC=Loose particle in container

Results relate only to the items tested.

CK ENVIRONMENTAL
Attention: Kevin Kelley
Client Project #: 3225
P.O. #:
Project name: BOIMASS COMBUSTION

Quality Assurance Report
Maxxam Job Number: GA7D8796

QA/QC Batch Num Init	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
1432143 LJD	Spiked Blank	Extractable Condensibles	2007/12/30	110, RDL=1	108	mg	70 - 130
	Spiked Blank DUP	Extractable Condensibles	2007/12/30	110, RDL=1	105	mg	70 - 130
	Method Blank	Extractable Condensibles	2007/12/30	ND, RDL=1	--	mg	
1434806 VP2	Method Blank	Non-Extractable Condensibles	2008/01/02	ND, RDL=0.5		mg	
1434814 VP2	Method Blank	Particulate Weight in Acetone Rinse	2008/01/02	ND, RDL=0.5		mg	

ND = Not detected
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A7D8796

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



FRANK MO, B.Sc., Inorganic Lab. Manager

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format. ...



CK ENVIRONMENTAL, INC.
 1020 Turnpike Street, Suite 8 Canton, Massachusetts 02021
 Phone 781.828-5200 Fax 781.828-5380

CHAIN OF CUSTODY DOCUMENT
 Page 1 of 1

CK Client Name: BioMass Combustion	Project Location	CK P.O. No.:	Laboratory
Project Name:	Boston Sash	Sample Date(s): 12/6/2007	Maxxam Analytical
CK Project No.: 3225	Dighton, MA	Date Shipped: 12/12/2007	
CK Project Manager: Kevin Kelley		Cooler No.: N/A	
CK Field Team: Kevin Kelley		COC Seal No.: N/A	Attn: Sample Custodian
Turnaround Time (Please Circle): Rush Priority Standard Other:			

Item	Sample ID Code	Date	Volume	Sample Location	Sample Fraction	Sample Matrix	Analytical Parameters	Special Instructions
1	Run 1	12/06/07			Filter #2006090606		PM by EPA M5	
2	Run 1	12/06/07			P&N rinse	acetone	PM by EPA M5	
3	Run 1	12/06/07			Impinger Catch & Rinse	DI water	CPM by EPA 202	
4	Run 1	12/06/07			MeCl2 Rinse	MeCl2	CPM by EPA 202	
5	Run 2	12/06/07			Filter #2006090604		PM by EPA M5	
6	Run 2	12/06/07			P&N rinse	acetone	PM by EPA M5	
7	Run 2	12/06/07			Impinger Catch & Rinse	DI water	CPM by EPA 202	
8	Run 2	12/06/07			MeCl2 Rinse	MeCl2	CPM by EPA 202	
9	Run 3	12/06/07			Filter #2006090605		PM by EPA M5	
10	Run 3	12/06/07			P&N rinse	acetone	PM by EPA M5	
11	Run 3	12/06/07			Impinger Catch & Rinse	DI water	CPM by EPA 202	
12	Run 3	12/06/07			MeCl2 Rinse	MeCl2	CPM by EPA 202	

Field Notes and Misc. Comments:

Sign & date C-O-C form and return original copy with final data report.

Relinquished by (Print Name): Kevin Kelley	Date: 12/12/2007	Received by: FEDEX	Date: 12/12/2007
Signature: <i>Kevin Kelley</i>	Time:	Fed. Ex. Office:	Time: Hrs
Relinquished by: FEDEX	Date:	Tel #:	Time: Hrs
Fed. Ex. Office:	Time:	Tracking #:	Time: Hrs
Tracking #:	Date:	Received by Lab (Print Name):	Date:
	Time:	Signature:	Time:

Analytical Laboratory Notes:
 COC Seal Intact: Yes No
 Cooler Temperature: _____ Degrees F
 Comments: